



<b>Boilers and Pressure Vessels Program</b>	Ref. No.: BPV-07-01	Rev. No.: 0
<b><u>DIRECTOR'S ORDER</u></b>	Effective Date: July 1, 2007	Issue Date:

**IN THE MATTER OF:**  
**THE *TECHNICAL STANDARDS AND SAFETY ACT, 2000*,**  
S.O. 2000, c. 16  
- and -  
**ONTARIO REGULATION 220/01 (Boilers and Pressure Vessels)**

**Subject:** Exemption for Air Conditioning Piping  
**Sent to:** Posted on TSSA's Web-Site

---

---

The Director, of the Boiler and Pressure Vessels Regulation, *Technical Standards and Safety Act, 2000*, S.O. 2000, c. 16, pursuant to his authority as provided for in Section 36.(3)(c) of the *Technical Standards and Safety Act, 2000*, hereby orders the following:

1. Notwithstanding subsection 2.(2)(i) of Ontario Regulation 220/01 (Boilers and Pressure Vessels), the regulation does not apply to refrigeration piping that has a capacity of three tons (11 kW) or less of refrigeration or a capacity of five tons (18 kW) or less of refrigeration in an air conditioning system.
2. This Order is effective on July 1, 2007.

\_\_\_\_\_  
Roy Martin  
Director, Boilers and Pressure Vessels Regulation  
*Technical Standards and Safety Act, 2000*