

Product Updates for Eligible HVAC Measures included in the Save on Energy Heating and Cooling Program – Coming July 2017

The IESO will be removing the CAC incentives for the SEER 14.5 & 15 (EER 12 & 12.5) from the program as of June 30, 2017 and will be introducing incentives for the following products starting July 1, 2017:

Eligible HVAC Measure	Details/Description	Incentive Amount
High efficiency furnace equipped with a variable speed ECM	Must replace an existing furnace	\$250.00
Circulator Pump Equipped with a variable speed ECM	Must be installed on a hydronic heating system and not on a DHW heater	\$30.00
Energy Star certified CAC system 18+ SEER	Must be 18 SEER or higher and 13 EER or higher	\$600.00
Ductless ASHP	- Must be 15 SEER or higher, 12.5 EER or higher and 8.5 HSPF or higher - For electrically heated homes only	\$1000.00
Ductless Multiport ASHP	- Must be 15 SEER or higher, 12.5 EER or higher and 8.5 HSPF or higher - For electrically heated homes only	\$1250.00 for one exterior unit and the first two interior units, plus \$250.00 for each additional interior unit attached to the same exterior unit up to a max. participant incentive of \$3000.00
Ducted ASHP	- Must be 15 SEER or higher, 12.5 EER or higher and 8.5 HSPF or higher - For electrically heated homes only	\$1250.00
Cold Climate Ductless ASHP	- Must be 15 SEER or higher, 12.5 EER or higher and 8.5 HSPF or higher - Must meet NEEP's Cold Climate Air Source Heat Pump Specification (NEEP, 2017 or more recent) and; - Have a COP at -15°C(5°F) greater than 2.0 at a max capacity operation and; - Maintain a max capacity at -15°C (5°F) that is greater than	\$1500.00

	<ul style="list-style-type: none"> or equal to 55% of maximum capacity at 8.3°C (47°F) - For electrically heated homes only 	
Cold Climate Ductless Multiport ASHP	<ul style="list-style-type: none"> - Must be 15 SEER or higher, 12.5 EER or higher and 8.5 HSPF or higher - Must meet NEEP's Cold Climate Air Source Heat Pump Specification (NEEP, 2017 or more recent) and; - Have a COP at -15°C(5°F) greater than 2.0 at a max capacity operation and; - Maintain a max capacity at -15°C (5°F) that is greater than or equal to 55% of maximum capacity at 8.3°C (47°F) - For electrically heated homes only 	<p>\$1900.00 for one exterior unit and the first two interior units, plus \$400.00 for each additional interior unit attached to the same exterior unit, up to a maximum participant incentive of \$4000.00</p>
Cold Climate Ducted ASHP	<ul style="list-style-type: none"> - Must be 15 SEER or higher, 12.5 EER or higher and 8.5 HSPF or higher - Must meet NEEP's Cold Climate Air Source Heat Pump Specification (NEEP, 2017 or more recent) - For electrically heated homes only 	\$4000.00
Adaptive Thermostat	<ul style="list-style-type: none"> -Must have heat pump lockout temperature control, which will be listed on eligible thermostat list approved by IESO (TBD) - For electrically heated homes only 	\$50.00