

1

September 12, 2023

Defect Inspector: [REDACTED]

OESC 2021 Rule 02-004 - Any person responsible for any installed, alteration, repair, or extension of any electrical equipment, shall obtain a notification of work from the Electrical Safety Authority.

no notification taken out for relocated A/C. Also replaced wiring from disconnect to A/C

Pour obtenir une version française du rapport, veuillez appeler 1-877-372-7233.